



**INSULATION DETAIL "A"**



**NOTE:**

2" RIGID INSULATION SHALL BE "Hi 60" EXTRUDED POLYSTYRENE BY DOW CO. OR APPROVED EQUAL CONTRACTOR SHALL INSULATE PER DETAIL WHEN SEWER COMES WITHIN 2' OF EXISTING OR PROPOSED CULVERTS. INSTALL PER MDOT SECT 653

**INSULATION DETAIL "B"**

OLD ORCHARD BEACH, PUBLIC WORKS DEPARTMENT  
 103 Smithwheel Road, Old Orchard Beach, ME. 04064  
 Phone: 934-2250 Fax: 934-5323



**INSULATION DETAILS**

DATE: Mar 16, 2006

SCALE: NOT TO SCALE