

### ADDENDUM NO. 3

**NOTICE is hereby given to prospective Bidders** of the following information, clarifications, and modifications to the Bidding Documents. The Bidding Documents remain unchanged except for modifications specifically indicated under Modifications. Bidders must acknowledge receipt of this Addendum in the Bid Form and comply with the requirements for submission of Bids as set forth in the Bidding Documents.

#### **INFORMATION**

The answers below are provided in response to questions and comments submitted by prospective Bidders.

*Please provide information on how to connect the type I and S fixtures to the recommended conduit and wire as the fixture cut sheets show a smaller diameter conduit entries on rack of these fixture types.*

Answer: Install rough in box section first, with conduit connection as follows:

- Provide fixtures with ¾" NPT fittings on the side of the box, catalog selection "CONDUIT ENTRIES= 3/4S"
- Step down conduit size with reducer on each conduit entry to first fixture box in the string
- Continue with ¾" conduit for each run between subsequent luminaires for remainder of installation
- Use duct sealant putty between fixtures to prevent water from cascading through fixtures if damage occurs, consistent with manufacturer instructions

For step light (Type "S"), provide back box option **or** deep masonry box to accommodate conduit entries. Follow all steps above for both Type "S" and Type "I" fixtures.

*Existing sprinkler zones may be in conflict with the width of the 10-foot walkway as the sprinkler zones have been installed north and south of the walkway with less than 10-foot separation in some locations. Will the project cover the cost if additional sprinkler zones require repair.*

Answer: The irrigation allowance value is intended to cover the new irrigation indicated on the Drawings and up to six additional zone replacements required. Contractor shall take care to minimize damage to existing irrigation from walkway installation but replacement of the zones in potential conflict has been incorporated in the allowance cost.

*Does the 10-foot walkway need to be 10-feet in all areas or can it be reduced to avoid conflict with sprinkler zones.*

Answer: The design at this time is to maintain 10-feet for the walkway. The walkway position may require minor adjustment to the north or south to only interfere with one zone in conflict areas.

This Addendum and items listed above are provided to Bidders in a single Portable Document Format (.PDF) on the website indicated in the email notice. **BIDDERS ARE REQUESTED TO ALLOW FOR ELECTRONIC “READ RECEIPT” AND CONFIRM RECEIPT OF THE ELECTRONIC FILE VIA A REPLY EMAIL.**

**Prepared and Issued by Woodard & Curran (Engineer) on behalf of Owner:**

Town of Old Orchard Beach